



CFS Oaklyn  
33 W. Haddon Avenue  
Oaklyn, NJ 08107

2/21/2022 9:55  
SAMPLE NUMBER: V1011  
DATE SAMPLED: 2/6/22  
DATE/TIME RECEIVED: 2/7/22 11:17  
COLLECTED BY: Client

## CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	DF	Lead	RL	Date/Time Analyzed
V1011-1	Pantry Sink F.D.	2/6/2022	11L14	1	0.0165	0.002	2/9/2022 16:18
V1011-2	Kitchen Sink F.D.	2/6/2022	11:16	1	0.0021	0.002	2/9/2022 16:23
V1011-3	Kitchen Ice Mach. F.D.	2/6/2022	11:18	1	0.0024	0.002	2/11/2022 14:58
V1011-4	Kitchen 3 Bay F.D.	2/6/2022	11:21	1	0.0031	0.002	2/9/2022 16:44
V1011-5	1st Fl. Children Bath 1 F.D.	2/6/2022	11:30	1	<0.002	0.002	2/9/2022 17:00
V1011-6	1st Fl. Children Bath 2 F.D.	2/6/2022	11:30	1	<0.002	0.002	2/9/2022 17:05
V1011-7	1st Fl. Water Ftn F.D.	2/6/2022	11:32	1	0.0092	0.002	2/9/2022 17:10
V1011-8	1st Fl. Womans Bath F.D.	2/6/2022	11:33	1	<0.002	0.002	2/9/2022 17:15
V1011-9	1st Floor Mens Bath F.D.	2/6/2022	11:33	1	<0.002	0.002	2/9/2022 17:20
V1011-10	1st Fl. Utility F.D.	2/6/2022	11:35	1	<0.002	0.002	2/9/2022 17:26
V1011-11	2nd Fl. Child Bath 1 F.D.	2/6/2022	11:47	1	<0.002	0.002	2/10/2022 11:02
V1011-12	2nd Fl. Child Bath 2 F.D.	2/6/2022	11:47	1	<0.002	0.002	2/10/2022 11:07
V1011-13	Staff Bath 2nd Fl. F.D.	2/6/2022	11:49	1	<0.002	0.002	2/10/2022 11:12
V1011-14	2nd Fl. Water Font. 1 F.D.	2/6/2022	11:51	1	0.0071	0.002	2/10/2022 11:17
V1011-15	2nd Fl. Water Font. 2 F.D.	2/6/2022	11:51	1	0.0068	0.002	2/10/2022 11:43
V1011-16	Classroom 1	2/6/2022	11:52	1	<0.002	0.002	2/10/2022 11:48
V1011-17	Classroom 2	2/6/2022	11:53	1	<0.002	0.002	2/10/2022 11:53
V1011-18	Classroom 3	2/6/2022	11:55	1	<0.002	0.002	2/10/2022 11:58
V1011-19	Classroom 4	2/6/2022	11:55	1	<0.002	0.002	2/10/2022 12:03
V1011-20	Classroom 5	2/6/2022	11:58	1	<0.002	0.002	2/10/2022 12:08
V1011-21	Classroom 6	2/6/2022	11:59	1	<0.002	0.002	2/10/2022 12:13

Latish Menghani  
Lab Director



CFS Oaklyn  
33 W. Haddon Avenue  
Oaklyn, NJ 08107

2/21/2022 9:55  
SAMPLE NUMBER: V1011  
DATE SAMPLED: 2/6/22  
DATE/TIME RECEIVED: 2/7/22 11:17  
COLLECTED BY: Client

## CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Time Sampled	DF	Copper	RL	Date/Time Analyzed
V1011-1	Pantry Sink F.D.	2/6/2022	11L14	1	0.294	0.05	2/17/2022 12:00
V1011-2	Kitchen Sink F.D.	2/6/2022	11:16	1	0.343	0.05	2/17/2022 12:03
V1011-3	Kitchen Ice Mach. F.D.	2/6/2022	11:18	1	0.342	0.05	2/17/2022 12:04
V1011-4	Kitchen 3 Bay F.D.	2/6/2022	11:21	1	0.255	0.05	2/17/2022 12:04
V1011-5	1st Fl. Children Bath 1 F.D.	2/6/2022	11:30	1	0.087	0.05	2/17/2022 12:05
V1011-6	1st Fl. Children Bath 2 F.D.	2/6/2022	11:30	1	0.456	0.05	2/17/2022 12:05
V1011-7	1st Fl. Water Ftn F.D.	2/6/2022	11:32	1	0.879	0.05	2/17/2022 12:06
V1011-8	1st Fl. Womans Bath F.D.	2/6/2022	11:33	1	0.267	0.05	2/17/2022 12:06
V1011-9	1st Floor Mens Bath F.D.	2/6/2022	11:33	1	0.223	0.05	2/17/2022 12:07
V1011-10	1st Fl. Utility F.D.	2/6/2022	11:35	1	0.277	0.05	2/17/2022 12:09
V1011-11	2nd Fl. Child Bath 1 F.D.	2/6/2022	11:47	1	0.375	0.05	2/17/2022 12:09
V1011-12	2nd Fl. Child Bath 2 F.D.	2/6/2022	11:47	1	0.248	0.05	2/17/2022 12:11
V1011-13	Staff Bath 2nd Fl. F.D.	2/6/2022	11:49	1	0.210	0.05	2/17/2022 12:11
V1011-14	2nd Fl. Water Font. 1 F.D.	2/6/2022	11:51	1	0.491	0.05	2/17/2022 12:12
V1011-15	2nd Fl. Water Font. 2 F.D.	2/6/2022	11:51	1	0.436	0.05	2/17/2022 12:17
V1011-16	Classroom 1	2/6/2022	11:52	1	0.261	0.05	2/17/2022 12:13
V1011-17	Classroom 2	2/6/2022	11:53	1	0.287	0.05	2/17/2022 12:13
V1011-18	Classroom 3	2/6/2022	11:55	1	0.172	0.05	2/17/2022 12:15
V1011-19	Classroom 4	2/6/2022	11:55	1	0.130	0.05	2/17/2022 12:16
V1011-20	Classroom 5	2/6/2022	11:58	1	<0.05	0.05	2/17/2022 12:17
V1011-21	Classroom 6	2/6/2022	11:59	1	<0.05	0.05	2/17/2022 12:17

Latish Menghani  
Lab Director