



CFS Headstart F.R.  
31 Fort Dix Road  
Pemberton, NJ 08068

5/3/2022 13:38  
SAMPLE NUMBER: V2484  
DATE SAMPLED: 4/10/22 09:30  
DATE/TIME RECEIVED: 4/11/22 15:40  
COLLECTED BY: Client (VEL)

## CERTIFICATE OF ANALYSIS

N.J.D.E.P. CERTIFICATION # 06003

Results in mg/l(ppm) unless otherwise noted

Sample #	Sample Location	Date Sampled	Sample Time	Lead	Date Analyzed	Copper	Date Analyzed
V2484-1	Ladies BR Sink	4/10/2022	9:30	<0.002	4/13/22 9:31	<0.05	4/28/22 14:27
V2484-2	Water Fountain #1	4/10/2022	9:35	<0.002	4/13/22 9:42	<0.05	4/28/22 14:28
V2484-3	Water Fountain #2	4/10/2022	9:38	<0.002	4/13/22 9:47	<0.05	4/28/22 14:28
V2484-4	Mews Front Sink	4/10/2022	9:40	0.0089	4/13/22 9:52	<0.05	4/28/22 14:31
V2484-5	Room 105 Sink	4/10/2022	9:43	0.0054	4/13/22 9:58	<0.05	4/28/22 14:32
V2484-6	Community Rm K/T	4/10/2022	9:45	<0.002	4/13/22 10:03	<0.05	4/28/22 14:32
V2484-7	Staff HK Bath Sink	4/10/2022	9:48	0.007	4/13/22 10:08	<0.05	4/28/22 14:33
V2484-8	Kitchen HW Sink	4/10/2022	9:50	0.0063	4/13/22 10:28	<0.05	4/28/22 14:34
V2484-9	Kitchen Prep Sink	4/10/2022	9:52	0.0041	4/13/22 10:38	<0.05	4/28/22 14:35
V2484-10	Kitchen 3 Bay Sink 1	4/10/2022	9:54	0.0096	4/13/22 10:43	<0.05	4/28/22 14:35
V2484-11	Kitchen 3 Bay Sink 2	4/10/2022	9:56	0.0122	4/13/22 10:48	<0.05	4/29/22 15:31
V2484-12	Classroom #1 Sink	4/10/2022	9:59	0.0035	4/13/22 10:53	<0.05	4/29/22 15:32
V2484-13	Classroom #2 Sink	4/10/2022	10:01	0.0073	4/13/22 10:59	<0.05	4/29/22 15:32
V2484-14	Classroom #1 BR	4/10/2022	10:03	0.0036	4/13/22 11:04	<0.05	4/29/22 15:33
V2484-15	Classroom #2 BR	4/10/2022	10:05	0.0091	4/13/22 11:09	<0.05	4/29/22 15:33

Latish Menghani  
Lab Director